

FIRE SAFETY CERTIFICATE

NO : 02 / 2026
R.C.NO: 21 / V / 2026

Dated: 03.01.2026

Certified that the BHARANI VIDHYALAYA at S.F.NO: 602/2,
BHARANI GARDENS, SALEM BYE PASS ROAD, VENNAIMALAI POST,
MANMANGALAM TALUK, KARUR comprised of NIL basement(s) and G+3
(upper floors) owned/ occupied by BHARANI VIDHYALAYA.

BHARANI VIDHYALAYA have complied with the fire safety requirements in
accordance with rule of state/UT Fire Service Rules, and verified by the officers
concerned of Fire Service on 07.01.2026 in the Presence of S.MOHANA RENGAN
and that the building / premises is fit for occupancy up to classes XII With effect
from 07.01.2026 for a period of THREE YEAR in accordance with rule and subject
to compliance of specific conditions as appended:-

CONDITIONS:

1. ALL Fire Fighting Equipment's should be Maintain Periodically and fire extinguishers should be installed and maintained as per IS 2190:2010
2. This certificate should be used only educational purpose.
3. This certificate is valid up to Three years from the Date of issue.
4. Every six months should be conducted fire mock drill and evacuations drill.
5. Building stability certificate should be renewed periodically. Or else this certificate will be Invalid Automatically
6. Emergency Exits should be provided from the upper floors.
7. Hose reel Hose system should be installed.

Issued on 07.01.2026 at PUGALUR by



Signature with seal: 
Name : Thiru. M.SARAVANAN,
Designation: STATION OFFICER,
Name and address of the Department/office:
Fire&Rescue Station, Pugalur,Karur Dist.

To:
The Correspondent,
Bharani Vidhyalaya, Bharani Gardens,
Salem Bye Pass Road, Vennaimalai Post,
Manmangalam Taluk, KarurDist .


PRINCIPAL,
BHARANI VIDHYALAYA,
AFF. No: 1930254, SCHOOL CODE: 55186,
BHARANI GARDENS, VENNAIMALAI (PO),
KARUR - 639 006. TAMILNADU.


CORRESPONDENT,
BHARANI VIDHYALAYA
BHARANI GARDENS,
VENNAIMALAI - POST,
KARUR - 639 006.